

Symbol Pomieszczenia	θi [°C]	Liczba grzejników	Φ [W]	Φwym [W]	Φop [W]	Φgrz [W]	Wynik. Φop [W]	Wynik. Φgrz [W]	Wynik. Φdz [W]	Pokrycie strat [%]
-------------------------	------------	----------------------	----------	-------------	------------	-------------	----------------------	-----------------------	----------------------	-----------------------

Kondygnacja 1, Rzędna 0,0m, Jednostka budynku 02

101	20	1 k	89	89	0	89	0	163	0	184
102	18	1 k	465	801	0	801	0	1000	0	125
103	24	1 k	201	201	0	201	0	200	0	99
104	20	BRAK	47	0	0	0	0	0	0	
105	5	BRAK	0	0	0	0	0	0	0	
106	20	1 k	740	787	0	0	0	780	0	99
107	20	3 k	3479	3479	0	0	0	3480	0	100
108	20	1 k	1195	1195	0	0	0	1190	0	100
109	20	2 k	1674	1674	0	0	0	1680	0	100
110	24	1 k	361	361	0	361	0	361	0	100
111	24	1 k	1220	1220	0	0	0	1210	0	99
112	24	1 k	1303	1303	0	0	0	1300	0	100
113	20	3 k	3746	3746	0	0	0	3720	0	99
114	20	BRAK	45	0	0	0	0	0	0	
115	20	1 k	1597	1597	0	0	0	1590	0	100
116	20	3 k	5669	5669	0	0	0	5610	0	99
117	24	1 k	508	508	0	508	0	508	0	100
118	20	1 k	386	386	0	386	0	386	0	100
119	20	1 k	307	307	0	0	0	700	0	228
120	20	1 k	119	321	0	321	0	320	0	100
121	20	BRAK	202	0	0	0	0	0	0	
122	20	BRAK	324	0	0	0	0	0	0	
123	20	1 k	121	445	0	445	0	445	0	100
124	16	2 k	455	940	0	940	0	1940	0	206
125	20	2 k	691	691	0	691	0	1391	0	201
126	20	1 k	289	289	0	289	0	289	0	100
127	20	4 k	5302	5302	0	0	0	5280	0	100
128	20	1 k	1236	1236	0	0	0	1230	0	100
129	20	1 k	1253	1253	0	0	0	1250	0	100
130	20	1 k	1129	1129	0	0	0	1130	0	100
131	24	1 k	386	386	0	386	0	386	0	100
132	24	1 k	374	374	0	374	0	374	0	100
133	20	BRAK	485	0	0	0	0	0	0	
134	20	1 k	1374	1374	0	0	0	1370	0	100
135	20	1 k	1238	1238	0	0	0	1240	0	100
136	24	1 k	370	370	0	370	0	370	0	100
137	20	BRAK	225	0	0	0	0	0	0	
138	20	BRAK	87	0	0	0	0	0	0	
139	20	1 k	1089	1089	0	0	0	1090	0	100
140	20	1 k	1617	1617	0	0	0	1600	0	99
141	20	2 k	1068	1828	0	0	0	1800	0	98
142	24	1 k	373	373	0	373	0	373	0	100
143	24	1 k	375	375	0	375	0	375	0	100
144	6	BRAK	0	0	0	0	0	0	0	
145	20	1 k	211	211	0	211	0	210	0	100
146	20	1 k	1776	1776	0	0	0	1770	0	100
147	15	BRAK	0	0	0	0	0	0	0	
148	20	1 k	1399	1399	0	0	0	1390	0	99
149	16	2 k	384	384	0	384	0	784	0	204

150	20	BRAK	403	0	0	0	0	0	0
151	20	3 k	3342	3342	0	0	0	3300	99
152	20	4 k	7701	7701	0	0	0	7600	99
153	20	2 k	1430	1430	0	1430	0	2840	199
154	20	1 k	1153	1153	0	0	0	1150	100

Kondygnacja 2, Rzędna 5,8m, Jednostka budynku 03

201	20	2 k	3780	3780	0	0	0	3780	100
202	20	1 k	1508	1508	0	0	0	1500	99
203	20	1 k	1994	1994	0	0	0	1980	99
204	20	3 k	2657	2657	0	0	0	2670	100
205	20	1 k	1250	1250	0	0	0	1250	100
206	20	3 k	3699	3699	0	0	0	3720	101
207	20	2 k	2946	2946	0	0	0	2960	100
208	20	1 k	2258	2258	0	0	0	2260	100
209	20	BRAK	92	0	0	0	0	0	0
210	16	1 k	529	529	0	0	0	530	100
211	18	BRAK	337	0	0	0	0	0	0
212	24	1 k	498	498	0	498	0	498	100
213	20	2 k	4132	4132	0	0	0	4140	100
214	20	2 k	3773	3773	0	0	0	3780	100
215	20	BRAK	95	0	0	0	0	0	0
216	20	BRAK	54	0	0	0	0	0	0
217	20	1 k	102	102	0	102	0	150	147
218	20	BRAK	150	0	0	0	0	0	0
219	20	2 k	3002	3002	0	0	0	3000	100
220	20	1 k	132	280	0	280	0	280	100
221	20	BRAK	148	0	0	0	0	0	0
222	20	1 k	1478	1478	0	0	0	1480	100
223	20	1 k	443	443	0	0	0	450	101
224	20	1 k	1453	1545	0	0	0	1550	100
225	20	1 k	443	443	0	443	0	443	100
226	18	BRAK	447	447	0	0	0	0	0
227	20	2 k	1482	1482	0	0	0	1500	101
228	20	1 k	1462	1462	0	0	0	1470	101
229	20	1 k	1168	1168	0	0	0	1170	100
230	20	2 k	1212	1212	0	0	0	1220	101
231	20	1 k	1623	1623	0	0	0	1630	100
232	20	3 k	4785	4785	0	0	0	4800	100
233	20	2 k	3399	3399	0	0	0	3400	100
234	20	2 k	3650	3650	0	0	0	3660	100
235	20	BRAK	219	0	0	0	0	0	0
236	20	1 k	129	348	0	348	0	348	100
237	20	3 k	6170	6468	0	0	0	6570	102
238	20	2 k	2753	2753	0	0	0	2740	100

Kondygnacja 3, Rzędna 10,5m, Jednostka budynku 04

301	20	1 k	1846	1846	0	0	0	1850	100
302	20	1 k	1652	1652	0	0	0	1660	100
303	18	BRAK	518	518	0	0	0	0	0
304	20	2 k	3640	3640	0	0	0	3640	100
305	20	2 k	3009	3009	0	0	0	3020	100
306	20	1 k	429	429	0	429	0	429	100
307	16	BRAK	0	0	0	0	0	0	0
308	20	1 k	763	763	0	0	0	770	101

309	15	BRAK	0	0	0	0	0	0	0	
310	24	1 k	515	515	0	515	0	515	0	100
311	20	1 k	2330	2330	0	0	0	2330	0	100
312	20	1 k	1372	1372	0	0	0	1380	0	101
313	20	1 k	1472	1472	0	0	0	1480	0	101
314	15	BRAK	0	0	0	0	0	0	0	
315	20	1 k	396	570	0	0	0	700	0	123
316	20	4 k	3415	3415	0	0	0	3440	0	101
317	20	1 k	1905	1905	0	0	0	1910	0	100
318	20	2 k	1815	1815	0	0	0	1820	0	100
319	16	2 k	3181	3181	0	3181	0	3181	0	100
320	20	BRAK	183	0	0	0	0	0	0	
321	20	1 k	2015	2105	0	0	0	2110	0	100
322	20	2 k	5206	5206	0	0	0	5200	0	100
323	20	2 k	3832	3832	0	0	0	3840	0	100
324	20	1 k	1414	1414	0	0	0	1420	0	100
325	20	1 k	2964	2964	0	0	0	2970	0	100
326	20	2 k	1410	1410	0	0	0	1420	0	101
327	20	1 k	2057	2150	0	0	0	2150	0	100
328	20	1 k	1641	1641	0	0	0	1650	0	101
329	5	BRAK	0	0	0	0	0	0	0	
330	20	1 k	129	278	0	278	0	278	0	100
331	20	BRAK	149	0	0	0	0	0	0	
332	20	BRAK	146	0	0	0	0	0	0	
333	20	BRAK	91	0	0	0	0	0	0	
334	20	BRAK	222	0	0	0	0	0	0	
335	20	1 k	157	157	0	157	0	200	0	128
336	20	1 k	127	349	0	349	0	349	0	100
337	20	1 k	223	223	0	223	0	223	0	100
338	16	BRAK	174	0	0	0	0	0	0	
339	20	2 k	3568	3568	0	0	0	3580	0	100
340	20	1 k	946	946	0	946	0	1000	0	106
341	20	4 k	6341	6578	0	0	0	6680	0	102

Kondygnacja 4, Rzędna 14,9m, Jednostka budynku 05