

zestawienie wody lodowej

Symbol Pomieszczenia	θ_i [°C]	Liczba grzejników	Φ [W]	Φ_{wym} [W]	Φ_{op} [W]	Φ_{grz} [W]	Wynik. Φ_{op} [W]	Wynik. Φ_{grz} [W]	Wynik. Φ_{dz} [W]	Pokrycie strat [%]
-------------------------	--------------------	----------------------	---------------	---------------------	--------------------	---------------------	------------------------------	-------------------------------	------------------------------	-----------------------

Kondygnacja 1, Rzędna 0,0m, Jednostka budynku 02

(bez nazwy)	20	BRAK	476	0	0	0	0	0	0	
(bez nazwy)	16	BRAK	567	0	0	0	0	0	0	
104	20	BRAK	88	0	0	0	0	0	0	
105	20	BRAK	813	0	0	0	0	0	0	
108	24	BRAK	199	0	0	0	0	0	0	
109	20	BRAK	46	0	0	0	0	0	0	
111	5	BRAK	0	0	0	0	0	0	0	
112	20	BRAK	609	0	0	0	0	0	0	
116	20	3 k	3453	0	0	0	0	5400	0	
119	20	1 k	1282	0	0	0	0	1800	0	
123	20	2 k	1664	0	0	0	0	2300	0	
126	24	BRAK	356	0	0	0	0	0	0	
127	24	1 k	1205	0	0	0	0	1700	0	
129	24	1 k	2225	0	0	0	0	1700	0	
130	20	3 k	3715	0	0	0	0	4800	0	
131	20	BRAK	44	0	0	0	0	0	0	
136	20	1 k	1675	0	0	0	0	900	0	
137	20	2 k	5526	0	0	0	0	4000	0	
138	24	BRAK	499	0	0	0	0	0	0	
139	20	BRAK	380	0	0	0	0	0	0	
140	20	1 k	182	0	0	0	0	1900	0	
141	20	4 k	7412	0	0	0	0	5400	0	
142	20	BRAK	118	0	0	0	0	0	0	
143	20	BRAK	200	0	0	0	0	0	0	
144	20	6 k	6008	0	0	0	0	10200	0	
145	20	BRAK	321	0	0	0	0	0	0	
146	20	BRAK	120	0	0	0	0	0	0	
147	16	BRAK	453	0	0	0	0	0	0	
148	20	BRAK	527	0	0	0	0	0	0	
149	20	BRAK	247	0	0	0	0	0	0	
153	20	4 k	5254	0	0	0	0	7400	0	
154	20	1 k	1323	0	0	0	0	1800	0	
155	20	1 k	1311	0	0	0	0	900	0	
156	20	1 k	1219	0	0	0	0	900	0	
157	20	BRAK	116	0	0	0	0	0	0	
158	20	BRAK	110	0	0	0	0	0	0	
159	20	BRAK	476	0	0	0	0	0	0	
160	20	1 k	1458	0	0	0	0	900	0	
161	20	1 k	1325	0	0	0	0	1300	0	
162	20	BRAK	109	0	0	0	0	0	0	
163	20	BRAK	222	0	0	0	0	0	0	
164	20	BRAK	86	0	0	0	0	0	0	
165	20	1 k	1173	0	0	0	0	1300	0	
166	20	1 k	1695	0	0	0	0	1700	0	
167	20	2 k	1266	0	0	0	0	900	0	
168	20	BRAK	110	0	0	0	0	0	0	
169	20	BRAK	112	0	0	0	0	0	0	
170	6	BRAK	0	0	0	0	0	0	0	

171	20	BRAK	67	0	0	0	0	0	0
172	20	1 k	1661	0	0	0	0	2600	0
173	14	BRAK	0	0	0	0	0	0	0
174	18	BRAK	207	0	0	0	0	0	0
175	20	1 k	1482	0	0	0	0	1700	0

Kondygnacja 2, Rzędna 5,8m, Jednostka budynku 03

(bez nazwy)	20	3 k	3954	0	0	0	0	3200	0
(bez nazwy)	20	2 k	1270	0	0	0	0	1600	0
201	20	2 k	3780	0	0	0	0	3600	0
203	20	1 k	1508	0	0	0	0	1500	0
204	20	BRAK	1973	0	0	0	0	0	0
205	20	3 k	2657	0	0	0	0	5500	0
206	20	1 k	1250	0	0	0	0	900	0
207	20	3 k	3699	0	0	0	0	3000	0
208	20	2 k	2946	0	0	0	0	3200	0
209	20	1 k	2257	0	0	0	0	2700	0
210	20	BRAK	92	0	0	0	0	0	0
211	16	BRAK	529	0	0	0	0	0	0
212	20	BRAK	665	0	0	0	0	0	0
213	24	BRAK	499	0	0	0	0	0	0
214	20	2 k	4132	0	0	0	0	1600	0
215	20	2 k	3773	0	0	0	0	1400	0
216	20	BRAK	95	0	0	0	0	0	0
217	20	BRAK	54	0	0	0	0	0	0
218	20	BRAK	102	0	0	0	0	0	0
219	20	BRAK	150	0	0	0	0	0	0
220	20	2 k	3002	0	0	0	0	3300	0
221	20	BRAK	132	0	0	0	0	0	0
222	20	BRAK	148	0	0	0	0	0	0
223	20	1 k	1478	0	0	0	0	700	0
224	20	1 k	443	0	0	0	0	500	0
225	20	1 k	1453	0	0	0	0	1500	0
226	20	BRAK	443	0	0	0	0	0	0
227	18	BRAK	459	0	0	0	0	0	0
228	20	2 k	1482	0	0	0	0	2300	0
229	20	1 k	1462	0	0	0	0	800	0
230	20	1 k	1168	0	0	0	0	1900	0
231	20	2 k	1212	0	0	0	0	2100	0
232	20	1 k	1623	0	0	0	0	1700	0
233	20	3 k	4785	0	0	0	0	4400	0
234	20	2 k	3399	0	0	0	0	3400	0
235	20	2 k	3650	0	0	0	0	3400	0
236	20	BRAK	219	0	0	0	0	0	0
237	20	BRAK	129	0	0	0	0	0	0

Kondygnacja 3, Rzędna 10,5m, Jednostka budynku 04

301	20	BRAK	1846	0	0	0	0	0	0
302	20	1 k	1652	0	0	0	0	1600	0
303	18	BRAK	518	0	0	0	0	0	0
304	20	2 k	3640	0	0	0	0	1900	0
305	20	2 k	3009	0	0	0	0	2200	0
306	20	BRAK	429	0	0	0	0	0	0
307	16	BRAK	0	0	0	0	0	0	0
308	20	1 k	764	0	0	0	0	1070	0

309	15	BRAK	0	0	0	0	0	0	0
310	24	BRAK	515	0	0	0	0	0	0
311	20	2 k	2330	0	0	0	0	2400	0
312	20	BRAK	214	0	0	0	0	0	0
313	20	1 k	1372	0	0	0	0	1700	0
314	20	1 k	1472	0	0	0	0	1800	0
315	14	BRAK	0	0	0	0	0	0	0
316	20	BRAK	401	0	0	0	0	0	0
317	20	4 k	3415	0	0	0	0	6800	0
319	20	1 k	1905	0	0	0	0	1800	0
320	20	2 k	1815	0	0	0	0	3500	0
321	16	BRAK	3184	0	0	0	0	0	0
322	20	1 k	183	0	0	0	0	1000	0
323	20	1 k	2015	0	0	0	0	1900	0
324	20	2 k	5206	0	0	0	0	2500	0
325	20	2 k	3832	0	0	0	0	2000	0
326	20	1 k	1414	0	0	0	0	1200	0
327	20	1 k	2962	0	0	0	0	2100	0
328	20	2 k	1410	0	0	0	0	2900	0
329	20	1 k	2057	0	0	0	0	1900	0
330	20	BRAK	1641	0	0	0	0	0	0
331	20	6 k	8593	0	0	0	0	7330	0
332	20	BRAK	738	0	0	0	0	0	0
333	5	BRAK	0	0	0	0	0	0	0
334	20	BRAK	129	0	0	0	0	0	0
335	20	BRAK	149	0	0	0	0	0	0
336	20	BRAK	146	0	0	0	0	0	0
337	20	BRAK	91	0	0	0	0	0	0
338	20	BRAK	222	0	0	0	0	0	0
339	20	BRAK	157	0	0	0	0	0	0
340	20	BRAK	127	0	0	0	0	0	0
341	16	BRAK	0	0	0	0	0	0	0

Kondygnacja 4, Rzędna 14,6m, Jednostka budynku 05